OMRON





Adjuster type standard that is the culmination of true ease and simplicity




Features

Self-explanatory LED bar displays of light levels

The previous manual type used the stability and incident level indicators to display the light level change, which was difficult to understand at a glance. The E3X-NA uses the LED bars to display the light level, ensuring the light level change at a glance.

Same "Wire-saving" Connector as E3X-DA-N


OMRON's original wiring-saving connector, which was inherited from the digital fiber amplifier E3X-DA-N, allows connection of up to 16 units.



E3X-NA




Conventional model



Features


Reduced wiring and space requirements for power lines

Example for 5 Amplifiers E3X-NA Series



Same Sensing Distance as Previous Longdistance Models

200 mm Reflective Models



Approximately Seven Times the Detection Accuracy


Applied Fiber: E32-T16P (screen fiber) set at 100 mm. E3X-A1 1 (previous model) Minimum detection object: 2.0 mm dia. E3X-NA 0.3 mm dia.

Applied Fiber: E32-T16 (screen fiber) set at 100 mm. E3X-A11 (previous model) 7 times E3X-NA Minimum detection object: 2.0 mm dia. → 0.3 mm dia.


Addition of high-speed type and waterproof type to the series

Optical Communications to Prevent Mutual Interference

Optical communication between amplifiers prevents mutual interference. Up to 5 fiber heads can be installed closely, except E3X-NA \square F.



Dimensions and Designs Inherited from the E3X-DA-N Digital Fiber Amplifier



OMRON

Ordering Information

Amplifier Units

Pre-wired

Item	Shape	Control output	Model		
nem	Shape		NPN output	PNP output	
Standard models	STA 11	ON/OFF output	E3X-NA11	E3X-NA41	
High-speed detection			E3X-NA11F	E3X-NA41F	
Mark-detecting models			E3X-NAG11	E3X-NAG41	
Water-resistant models			E3X-NA11V	E3X-NA41V	

Connector type

Item	Shape	Applicable Connector		Control output	Model	
Shape		(order separately)		Control output	NPN output	PNP output
Standard models		Master	E3X-CN11		E3X-NA6	E3X-NA8
Standard models		Slave	E3X-CN12	ON/OFF output		
Water-resistant models (M8 Connector)		XS3F-M421-40□-A XS3F-M422-40□-A			E3X-NA14V	E3X-NA44V

Amplifier Units Connectors (Order Separately) Note: Stickers for Connectors are included as accessories.

Item	Shape	Cable length	No. of conductors	s N	lodel	
Master connector	Í.	2 m	3	E3>	(-CN11	
Slave connector		2 11	1	E3>	(-CN12	
Precautions for ordering the connector type Amplifier Units Applicable Connector (order separately						
Refer to the following tables wh	en placing an order. Basical-	Type NPN	PNP +	Master connector	Slave connector	
ly, Amplifier Units and connectors are sold separately.		Standard E3X-NA6	E3X-NA8	E3X-CN11 (3 wires)	E3X-CN12 (1 wire)	
Please place an order after referring to the combination giv- When Using 5 Amplifier Units						
		Amplifier Units	(5 Units) +	1 Master Connector	+ 4 Slave Connectors	

Sensor I/O Connectors (Order separately)

Size	Cable type	Shape		Cable length		Model	
		Straight		2 m		XS3F-M421-402-A	
MO	M8 Standard cable	Straight	C Without	5 m	4 conductors	XS3F-M421-405-A	
IVIO		L-shapod		2 m		XS3F-M422-402-A	
		L-shaped		5 m	1	XS3F-M422-405-A	

Note: Refer to page NB-6 for details.

Accessories (Order Separately)

Mounting Brackets

Shape	Applicable type	Model	Quantity
Se of	E3X-NA□ E3X-NA□F E3X-NAG□	E39-L143	1
	E3X-NA⊡V	E39-L148	

End Plate

Shape	Model	Quantity
Desire of	PFP-M	1

Rating/performance

Amplifier Units

			Pre-	Connector type					
	Туре	Standard models	High-speed de- tection models	Mark-detecting models	Water-resistant models	Standard models	Water-resistant mod els (M8 Connector)		
Model	NPN output	E3X-NA11	E3X-NA11F	E3X-NAG11	E3X-NA11V	E3X-NA6	E3X-NA14V		
Item	PNP output	E3X-NA41	E3X-NA41F	E3X-NAG41	E3X-NA41V	E3X-NA8	E3X-NA44V		
Light source length)	(wave	Red LED (680 nm)	Green LED (520 nm)	Red LED (680 nm	n)			
Power supply age	y volt-	12 to 24 VDC ±10	%, ripple (p-p): 109	% max.					
Current cons	umption	35 mA max.	35 mA max. (at power supply voltage 24 VDC)	35 mA max.					
Control outpu	ut		A (residual voltage DN/Dark-ON switch		pen collector outpu	t type (depends on	the NPN/PNP out-		
Response tir	ne	Operation or re- set: 200 s max. *	Operating: 20 s max. Reset: 30 s max.	200 s max. for o	peration and reset	respectively (See n	ote.)		
Sensitivity ac ment	ljust-	8-turn endless adj	uster (with indicato	r)					
Protective circuits		Reverse polarity protection, out- put short-circuit Reverse polarity protection, mutu- al interference put short-circuit protection, out- prevention (opti- cally synchro- nized) Reverse polarity protection, output short-circuit protection, mutual interfer ence prevention (optically synchronized)							
Timer functio	n	OFF-delay timer: 4	40 ms (fixed)						
Ambient illun	ninance	Incandescent lam	p: 10,000 lux max.	Sunlight: 20,000 lu	x max.				
Ambient tem	perature	Operating: Groups of 1 to 3 Amplifiers: -25 to +55°C, Groups of 4 to 11 Amplifiers: -25 to +50°C, Groups of 12 to 16 Amplifiers: -25 to +45°C Storage: -30 to +70°C (with no icing and condensation)							
Ambient hurr	nidity	Operating/Storage: 35% to 85% RH (with no condensation)							
Insulation res	sistance	20 M min. at 500 VDC							
Dielectric stro	ength	1,000 VAC at 50/6	500 VAC at 50/60 Hz for 1 minute						
Vibration res	istance	10 to 55 Hz with a 1.5 mm double amplitude for 2 hrs each in X, Y and Z directions							
Shock resista	ance	Destruction: 500 n	n/s ² for 3 times ead	ch in X, Y, and Z di		1	I		
Protective structure		IEC 60529 IP50 (with Protective Cover attached)			IEC 60529 IP66 (with Protective Cover attached)	IEC 60529 IP50 (with Protective Cover attached)	IEC 60529 IP66 (with Protective Cover attached)		
Connection method		Pre-wired models	Connector type	M8 connector					
Weight (Pack state)	ked	Approx. 100 g			Approx. 110 g	Approx. 55 g	65 g		
	Case	PBT (polybutylene	e terephthalate)						
Material	Cover	Polycarbonate			Polyethersul- fone (PES)	Polycarbonate	Polyethersul- fone (PES)		
Accessories		Instruction manual							
			response time will be 3						

* If 8 or more Units are installed side-by-side, the response time will be 350 s max.

OMRON


Amplifier Unit Connectors


Item	Model	E3X-CN11 E3X-CN12					
Rated current 2.5 A							
Rated voltage 50 V							
Contact resistance 20 m max. (20 mVDC max., 100 mA max.) [By connection with amplifier unit and connection with adjacent nector (except conductor resistance of cable)]							
No. of insertions 50 times (By connection with amplifier unit and connection with adjacent connector)							
Materi-	Housing	PBT (polybutylene terephthalate)					
al	Contacts	Phosphor bronze/gold-plated nickel					
Weight (Packed state)		Approx. 55 g	Approx. 25 g				

Characteristic data (typical)


Number of Turns of Sensitivity Adjuster

vs. Sensing Distance E32-T11L





Sensing Distance vs. Hysteresis E32-T11L



E32-D11L


E3X-NHotline: 1900.6536 - Website: HOPLONGTECH.COM A-445

Output Circuit Diagram


NPN output

Model	Operating status of output transistor	Timing chart	Mode selec- tion switch	Output circuit
E3X-NA11 E3X-NA6 E3X-NAG11	Light ON	Incident Interrupted Operation ON (orange) OFF Output ON transistor OFF Load Operate (Relay) Reset (Between brown and black)	L ON (LIGHT ON)	Operation indicator (orange) Main circuit Black Control output Blue Blue
E3X-NA11F E3X-NA11V E3X-NA14V	Dark ON	Incident Interrupted Operation ON Indicator OFF Output ON transistor OFF Load Operate (Relay) Reset (Between brown and black)	D ON (DARK ON)	M8 Connector Pin Arrangement

PNP output



Connectors (Sensor I/O connectors)



Note: Pin 2 is not used.

Nomenclature:

Amplifier Units




Operation Mode Selector Use to switch between Light ON and Dark ON modes. Timer switch ON: Timer function is ON. OFF: Timer function is OFF.

Operation

Indicator status

In addition to the operation indicator (orange), E3X-NA has indicators that denotes the incident level (4 green and 1 red indicators). Use them for optical axis adjustment and maintenance.



Note: The rightmost indicator is turned ON at the "0 incident level".

Precautions

Correct Use

ito

Amplifier Units Design

Communications Hole


The window provided in the side face of the unit is a communication window for prevention of mutual interference when it is connected with the other unit. Note that the optional Mobile Console E3X-MC11 cannot be used. When the incident level of the sensor is excessive, mutual interference prevention may not be activated. At that time, make adjustment with the sensitivity adjuster. When the unit is used with the E3X-DA-N series, mutual interference prevention is not activated.


Mounting

Connection/removing of amplifier units

(Connection)

1. Install the Amplifier Units one at a time onto the DIN track.





(Removing)

Slide one unit away from the other and remove them one by one. (Do not remove the connected units together from the DIN rail.)

Note: 1 . When the amplifier units are interconnected, the operating ambient temperature changes depending on the number of connected amplifier units. Check "Ratings/Performance".
2 . Before connecting or removing the units, always switch power off.

Operating Environment

Ambient Conditions

Always remove dust, dirt, etc. from the optical communication window, which may disable communication.

Miscellaneous

Protective Cover


Be sure to set the Protective Cover before use.

OMRON


Amplifier Unit Connectors Installation

Installation Connectors

1. Insert the Master or Slave Connector into the Amplifier Unit until it clicks into place.



- 2. Join Amplifier Units together as required after all the Master and Slave Connectors have been inserted.
- 3. Apply the supplied seal to the non-connection surface of the master/slave connector.




Note: Apply the seal to the grooved side.

Removing Connectors

- 1. Slide the slave Amplifier Unit for which the Connector is to be removed away from the rest of the group.
- 2. After the Amplifier Unit has been separated, press down on the lever on the Connector and remove it. (Do not attempt to remove Connectors without separating them from other Amplifier Units first.)


Mounting End Plate (PFP-M)

Depending on the installation type, an Amplifier Unit may move during operation. In this case, use an End Plate. Before installing an End Plate, remove the clip from the master Amplifier Unit using a nipper or similar tool.



The sensor bottom is also equipped with the clip removing mechanism.

1. Insert the clip to be removed into the slit underneath the clip on another Amplifier Unit.




2. Remove the clip by rotating the Amplifier Unit.




Pull Strengths for Connectors (Including Cables) E3X-CN11: 30 N max. E3X-CN12: 12 N max.


Dimensions (Unit: mm)

Amplifier Units





OMRON



INDUSTRIAL AUTOMATION



INDUSTRIAL AUTOMATION

ALL DIMENSIONS SHOWN ARE IN MILLIMETERS.

To convert millimeters into inches, multiply by 0.03937. To convert grams into ounces, multiply by 0.03527.

Cat. No. E23E-EN-01

In the interest of product improvement, specifications are subject to change without notice.